

BRE Global Ireland

Notified Body No. 2831

BRE Global Assurance (Ireland) Limited
DCU Alpha, Old Finglas Road
Glasnevin, Dublin, D11 KXN4
Ireland
T: +353 (0) 18824344
E: enquiries@breglobalireland.ie
www.breglobalireland.ie

Certificate of constancy of performance

2831-CPR-F4467

In compliance with Regulation (EU) No. 305/2011 of the European Parliament and of the Council of 9th March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product(s)

BGL-xC-Ixx Addressable Type A Detector Base Strobe

(For full product details and conditions of use refer to appendix)

Placed on the market under the name or trade mark of:

Honeywell Products & Solutions Sàrl
(Trading as System Sensor Europe)
Zone d'activités La Pièce 16
CH-1180
Rolle
Switzerland

and produced in the manufacturing plant(s):

KAC Alarm Company Limited
Thornhill Road
North Moons Moat
Redditch
B98 9ND
United Kingdom

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

EN 54-17:2005 - Short circuit isolators

EN 54-23:2010 - Visual alarm devices

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure

the constancy of performance of the construction product.

This certificate was first issued on 30 November 2020 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.



P Halligan, Certification Engineer

Date of First Issue: 30 November 2020

Date of Issue: 30 November 2020

On behalf of BRE Global Assurance (Ireland) Limited

Issue number 01

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email enquiries@breglobalireland.ie

BRE Global Ireland**Notified Body No. 2831**

BRE Global Assurance (Ireland) Limited
DCU Alpha, Old Finglas Road
Glasnevin, Dublin, D11 KXN4
Ireland

T: +353 (0) 18824344

E: enquiries@breglobalireland.ie
www.breglobalireland.ie

APPENDIX to Certificate of constancy of performance: 2831-CPR-F4467**BGL-xC-lxx Addressable Type A Detector Base Strobe****Notes:**

1. The Ceiling mounted VAD meets the requirements of EN 54-23:2010 for the following:

- Category rating C-3-8.5
- Synchronization
- Flash rate 0.5Hz
- Red LED
- Clear lens

2. x indicates body colour. D=Detector White, P=Pure White

3. xx indicates customer and associated communication protocol.

01 indicates Advanced Protocol (and Honeywell 500 series protocol)

00 and 02-99 indicates Advanced Protocol (and System Sensor 500 series protocol)



P Halligan, Certification Engineer,

On behalf of BRE Global Assurance (Ireland) Limited

Date of First Issue: 30 November 2020

Date of issue: 30 November 2020

Issue number: 01

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email enquiries@breglobalireland.ie