



**Notified body No. 1134**  
asbl ANPI vzw  
Parc Scientifique Fleming - Granbonpré 1  
B-1348 Louvain-la-Neuve

## **CERTIFICATE OF CONSTANCY OF PERFORMANCE**

**1134 - CPR – 085**

In compliance with *Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011* (the products Construction Products Regulation or CPR), this certificate applies to the construction product:

### **Power Supply Equipment – Integrated in cabinet**

**Honeywell HLS PS50**

Variants:

**Honeywell HLS PS25**

with the performances listed in annex 1 of the EC certificate of constancy of performance and intended use: Fire safety

**manufactured by:**

**HONEYWELL LIFE SAFETY IBERIA**  
C/Pau Vila, 15-19  
Es - 08911 Badalona - BARCELONA  
Spain

**and produced in the manufacturing plant(s):**

**HONEYWELL LIFE SAFETY ROMANIA**  
Salcamilor 2 bis  
305500 Lugoj  
Romania

This certificate attests that all provisions concerning the assessment and the verification of constancy performance at system 1 being certified and the performances described in Annex ZA of the standard(s):

**EN 54-4:1997/AC:1999/A1:2002/A2:2006**

are applied and that

**the product fulfils to all here above mentioned and prescribed requirements.**

This certificate was first issued on **2010-02-08** and remains valid as long time as the testing methods and/or for the control of the production in factory included in the harmonized standard, used to evaluate the performances of the declared characteristics, do not change and as neither the product, nor the manufacturing conditions in the plant or the factory production control itself are not modified significantly.

**Brussels, the 5<sup>th</sup> of August 2015**

**Michèle VANDENDOREN**  
**Secretary General**

**This certificate and the annex may only be copied completely and without any adding**

Phone : +32 10 47 52 11 – Fax : +32 10 47 52 70 - [www.anpi.be](http://www.anpi.be)



**Notified body No. 1134**  
 asbl **ANPI** vzw  
 Parc Scientifique Fleming - Granbonpré 1  
 B-1348 Louvain-la-Neuve

**Annex 1 to CERTIFICATE CONSTANCY OF PERFORMANCE**  
**1134 - CPR – 085**

<i>Harmonised technical specification</i>	<b>EN 54-4:1997 + A1:2002 + A2:2006</b>	
<b>Essential Characteristics</b>	<b>Performance <sup>1) 2)</sup></b>	<b>Clause</b>
<i>Performance of power supply</i>		
- General requirements	pass	4
- Functions	pass	5
- Materials, design and manufacture	pass	6
<i>Operational reliability</i>		
- General requirements	pass	4
- Functions	pass	5
- Materials, design and manufacture	pass	6
- Documentation	pass	7
- Marking	pass	8
<i>Durability of operational reliability, temperature resistance</i>		
- Cold (operational)	pass	9.5
<i>Durability of operational reliability, vibration resistance</i>		
- Impact (operational)	pass	9.7
- Vibration, sinusoidal (operational)	pass	9.8
- Vibration, sinusoidal (endurance)	pass	9.15
<i>Durability of operational reliability, electrical stability</i>		
- Electromagnetic compatibility (EMC), immunity tests (operational)	pass	9.9
<i>Durability of operational reliability, humidity resistance</i>		
- Damp heat, steady state (operational)	pass	9.6
- Damp heat, steady state (endurance)	pass	9.14
1) "NPD" theoretically possible; except for durability of characteristics with declared performance		
2) "NA" not applicable for components to which the requirement does not apply		

**Brussels, the 5<sup>th</sup> of August 2015**

**Michèle VANDENDOREN**  
**Secretary General**

**This certificate and the annex may only be copied completely and without any adding**  
 Phone : +32 10 47 52 11 – Fax : +32 10 47 52 70 - [www.anpi.be](http://www.anpi.be)